



Linda S. Adams  
Secretary for  
Environmental Protection

# California Regional Water Quality Control Board

## San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties  
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger  
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353  
(858) 467-2952 • Fax (858) 571-6972  
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

June 17, 2010

In reply refer to:  
**Adai:237543**

Mr. Wally Grabbe, P.E.  
District Engineer  
Valley Center Municipal Water District  
29300 Valley Center Road  
Valley Center, CA 92082

Dear Mr. Grabbe:

**SUBJECT: LOWER MOOSA CANYON WATER RECLAMATION FACILITY**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the April-June 2009, July-September 2009, October-December 2009, and January-March 2010 quarterly monitoring reports; the January-June 2009 and July-December 2009 semiannual monitoring reports; and the January-December 2009 annual monitoring report submitted by the Valley Center Municipal Water District in accordance with Monitoring and Reporting Program of Order No. 95-32.

The following violations of the Order No. 95-32 were identified in the above monitoring reports:

1. The daily maximum discharge specification for Biochemical Oxygen Demand (BOD) established at 30 milligrams per liter (mg/L) was exceeded on April 22 and May 6, 2009, and January 7, 2010 with reported values of 65, 31, and 35 mg/L respectively.
2. The 30-day average discharge specification for BOD established at 20 mg/L was exceeded for April and May 2009 with reported values of 27.72 and 21.85 mg/L respectively.
3. The daily maximum discharge specification for total suspended solids established at 30 mg/L was exceeded on April 22, 2009 with a reported value of 47 mg/L.

*California Environmental Protection Agency*



Mr. Wally Grabbe  
Lower Moosa Canyon WRF

- 2 -

June 17, 2010

Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;<sup>1</sup> referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring reports required to be submitted are the April-June 2010 quarterly and January-June 2010 semiannual monitoring reports which are due by July 30, 2010.

In the subject line of any response, please include the requested "in reply refer to" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Ms. Amanda Dai at (858) 627-3977 or via email at [adai@waterboards.ca.gov](mailto:adai@waterboards.ca.gov).

Sincerely,

*Robert Morris*

Robert Morris, P.E.  
Senior Water Resource Control Engineer  
Groundwater Branch

**Regulatory Measure ID 374528**

**Violation ID 1) 872937, 872938, 872939, 2) 872940, 872941, 3) 872942**

---

<sup>1</sup> Under authority of California Water Code section 13350.

*California Environmental Protection Agency*

 Recycled Paper